



# Dawson County Emergency Services

Lanier Swafford, Director  
 Tim Satterfield, Deputy Chief  
 Ricky Rexroat, Deputy Chief  
 Danny Speaks, Asst. Chief

393 Memory Lane  
 Dawsonville, Georgia 30534  
 (706) 344-3666 Office  
 (706) 344-3669 Fax

## DAWSON COUNTY EMERGENCY SERVICES TENT PERMIT CONDITIONS

Date Issued: \_\_\_\_\_

Name of Vendor/Renter: \_\_\_\_\_

Location of Tent: \_\_\_\_\_

Date (s): \_\_\_\_\_

The following conditions will apply to all tents erected within Dawson County except that tents of less than 1000 square feet in an area shall be exempt. If fireworks are involved, or if materials are present that may create a hazardous environment, an inspection shall be performed by Dawson County Emergency Services.

Check One	Tent Area (sq. ft)	Fire Extinguisher	Main Aisle Width	Exits
_____	>1000 but <3000	1	44 inches	2
_____	>3001 but <6000	2	44 inches	2
_____	>6001 but <9000	3	66 inches	3
_____	>9001 but <12000	4	88 inches	3

If tent is to be used during the evening hours or with closed sides, the following Additional requirements shall apply:

- a. Emergency lighting shall be installed throughout
- b. Illuminated exit lights shall be installed at each exit

If you have any questions concerning these conditions, please contact the Fire Marshal's Office at (706) 344-3666, ext. 229.



DATE: \_\_\_\_\_

The following individuals have reviewed the request and their recommendations are as indicated:

<u>Department</u>	<u>Recommendation</u>	<u>Initials/Date</u>
Dawson County Fire Marshal	Grant/Deny	_____
Dawson County Sheriff	Grant/Deny	_____
Dawson county Health Dept.	Grant/Deny	_____
Planning & Development	Grant/Deny	_____

Is tent to be placed on Dawson County Property?  
 (If yes, then applicant must have Parks & Recreation approval) Yes \_\_\_\_\_ NO \_\_\_\_\_

Parks & Recreation	Grant/Deny	_____
--------------------	------------	-------

Comment/Remarks

Site Plan Description  
 Copy of Certification of Flame Resistance